

SEQUIM BUILDING CODES HAVE CHANGED

15.04.085 Propane tank regulations.



◆ Section 5703.6 of the International Fire Code is amended as follows:

- Piping Systems. Piping systems, and their component parts, for flammable and combustible liquids must be in accordance with Section 5703.6.1 through 5703.6.11. Piping for above ground Liquid Propane systems greater than or equal to 125-gallons must be of approved flexible connect tubing from the tank to the appliance.

◆ Section 6107 of the International Fire Code adds three new sections to read as follows:

- SECTION 610
- SAFETY PRECAUTIONS AND DEVICES
- 6107.5 Protecting containers from displacement. LP-gas containers greater than or equal to 125-gallons must be anchored or strapped to prevent lateral displacement. Anchors or straps must be an approved, listed device. Anchors or straps for LP-gas containers greater than or equal to 2000-gallons must be designed by a licensed professional.
- 6107.6 Earthquake shut-off valves. LP-gas containers greater than or equal to 125-gallons must be protected with an approved, listed earthquake shut-off device.
- 6107.7 Non-compliant installed LP-gas containers. Non-compliant LP-gas containers must comply with Sections 6107.5 and 610.7.6 when a change of use / occupancy occurs.

◆ (Ord. 2017-008 § 1 (Exh. A))

